

Supplier	TOSHIBA CARRIER CORPORATION
----------	-----------------------------

Unutarnja jedinica	RAS-24J2KVG-E
--------------------	---------------

Vanjska jedinica	RAS-24J2AVG-E
------------------	---------------

Sound power level

Unutarnja jedinica (hlađenje)	dB	63
-------------------------------	----	----

Vanjska jedinica (hlađenje)	dB	70
-----------------------------	----	----

Unutarnja jedinica (grijanje)	dB	58
-------------------------------	----	----

Vanjska jedinica (grijanje)	dB	70
-----------------------------	----	----

Radni medij

Tip		R32
-----	--	-----

Potencijal globalnog zatopljenja	kgCO ₂ eq	675
----------------------------------	----------------------	-----

Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to 1975. This means that if 1 kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be 1975 times higher than 1 kg of CO₂, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional.

Cooling

Energy efficiency class		A++
-------------------------	--	-----

Design load (P _{designc})	kW	6.5
-------------------------------------	----	-----

Seasonal efficiency (SEER)		6.10
----------------------------	--	------

Sezonska snaga električnog priključka (Q _{CE})	kWh/annum	373
--	-----------	-----

Heating

		Heating/Average	Heating/Warmer	Heating/Colder
Energy efficiency class		A+	A++	x
Design load (Pdesignh)	kW	5.4	2.9	x,x
Seasonal efficiency (SCOP)		4.00	4.90	x,xx
Sezonska snaga električnog priključka (Q _{HE})	kWh/annum	1890	824	x
Pričuvni kapacitet grijanja	kW	1.02		
Navedeni kapacitet grijanja pri sobnoj temperaturi od 20° C i vanjskoj temperaturi zraka (Tj)				
Tj= -7°C (Pdh)	kW	4.78	-	x,xx
Tj= 2°C (Pdh)	kW	2.91	2.91	x,xx
Tj= 7°C (Pdh)	kW	1.87	1.87	x,xx
Tj= 12°C (Pdh)	kW	0.90	0.90	x,xx
Tj=bivalent temperature (Pdh)	kW	4.78	2.91	x,xx
Tj=granična radna temperatura (Pdh)	kW	3.71	3.71	x,xx
Tj= -15°C (Pdh)	kW	-	-	x,xx